



NOTE
 FOR CP5x, CPLT, CPST & EPxx
 SET SWITCH 1 TO POSITION 0
 FOR ALL OTHER C.P
 PRODUCTS SET SWITCH 1
 TO POSITION 1.

NOTES

- INPUT STATES ARE AS FOLLOWS:-
 CLOSED CONTACT = RUNNING
 OPEN CONTACT = NOT RUNNING
- CON3 TERMINAL 9 MUST HAVE
 NEUTRAL CONNECTED TO IT.
- TO ENSURE THAT INTERNALLY FITTED
 SUPPRESSORS WORK CORRECTLY, CONNECT
 LINE VOLTAGES TO TERMINALS PREFIXED
 'LN' AND THE CORRESPONDING LOADS TO
 TERMINALS PREFIXED 'LD'.
- WHEN THE NUMBER OF STEPS PROGRAMMED
 EXCEEDS 7 REFER TO THE RELEVANT
 COMPRESSOR PACK MANUAL FOR DETAILS
 OF RELAY SEQUENCING.
- SWITCH SETTINGS
 THE POSITION OF THE DIP SWITCHES 'SW2'
 MUST BE SET AS SHOWN (IE: DOT SHOWING
 CLOSED CONTACT ON TWO RIGHT HAND)
 FOR THE CARD TO OPERATE CORRECTLY.

SWITCHES 'SW3' CONTROL THE OUTPUT
 RELAYS IF PACK SERIAL DATA BUS
 COMMUNICATIONS FAIL. (CLOSED DOT
 SHOWING = RELAY ENERGISED).

JTL SYSTEMS LTD. 41 KINGFISHER COURT, HAMBRIDGE RD, NEWBURY, BERKSHIRE. RG14 5SJ TEL: 01635-263646 FAX: 01635-263647			
ISS	DESCRIPTION	APP'D	DATE
4	ADDED NOTE FOR SWITCH 1	MJK	9/96
3	REDRAWN - NOTES ADDED	NMT	5/91
5	ADDED NEW PRODUCT EPxx	MJK	4/02

TITLE: **CONDENSER INTERFACE WIRING
 (FOR CPxx & EPxx CONTROLLERS)**

TYPE: IF-1				
PROJ.	DRG No.	SHT	OF	ISS.
CP/EP	00122	1	1	5

THIS IS AN UNCONTROLLED COPY - UNLESS STAMPED WITH CONTROLLED COPY STAMP