



Application Drawing for Defrost System Interface - IF13 For Legacy Pack Controllers

NOTE:

WHERE DRAIN DOWN BOARDS ARE USED WIRING FOR EACH SYSTEM MUST BE AS FOLLOWS.



CONFIGURATION

ITEM 31 (Interface Type)		ITEM 30 (Interface No.)									
DEFROST	DRAIN DOWN	DEFROST	DRAIN DOWN	7	6	5	4	3	2	1	
4	4	2	6	14	13	12	11	10	9	8	
		3	7	21	20	19	18	17	16	15	
		4	8	28	27	26	25	24	23	22	
		5	9								

DEFROST SYSTEM NO.

NOTES:

- CONTACTS SHOWN IN REFRIGERATION/NON DRAIN DOWN STATE (NORMALLY CLOSED).
- ENSURE THAT INTERNALLY FITTED SUPPRESSORS WORK CORRECTLY, CONNECT LINE VOLTAGES TO TERMINALS PREFIXED 'C' (COMMON) AND CORRESPONDING LOADS TO TERMINALS 'NO' & 'NC'.
- SWITCH SETTINGS**
SWITCHES SW1 CONTROL THE OUTPUT RELAYS IF PACK SERIAL DATA BUS COMMUNICATIONS FAIL. SWITCH CLOSED (ON) = RELAY ENERGISED.
- A MAINTENANCE UNIT IS REQUIRED TO CONFIGURE THIS PRODUCT.
- FOR NEWER PACK CONTROLLERS SEE ALTERNATIVE DRG. 02779.



JTL SYSTEMS LTD
41 KINGFISHER COURT, HAMBRIDGE RD,
NEWBURY, BERKSHIRE: RG14 5SJ
TEL: 01635 263646 FAX: 01635 263647

ISSUE	DESCRIPTION	APP'D	DATE
1	ORIGINAL ISSUE	MJK	09/02

TITLE:
DEFROST SYSTEM INTERFACE
FOR LEGACY PACK CONTROLLERS - IF13

PROJ.	DRG No:	SHT	OF	ISS.
	02819	1	1	1

THIS IS AN UNCONTROLLED COPY - UNLESS STAMPED WITH CONTROLLED COPY STAMP