



## Christmas lighting times and dial out changes for Morrisons

Where dial out is activated by JTL rather than CDK for all days that the stores are closed all day and unmanned, dial out settings must be changed in unit 907. In screenshot 1 you can see when daytime starts and finishes. During daytime dial outs do not occur. Daytime finish needs to be set to 5 minutes after whatever time daytime starts. In this example for days that Morrisons are closed you would set daytime finish to 08:05. Daytime start and finish are always set in unit 907.


All changes must be reverted after the Christmas period.

Your engineer's will need swipe cards to make changes. All stores are viewable remotely via the JTL Cloud or SiteEngineer so you can see how sites are currently set up.




Screenshot 1

The case lighting changes should be made to unit 901 Store trading hours. We suggest that you only lengthen opening hours to ensure that the store lights operate correctly in the second week. Screenshot 2 shows the current lighting schedule for Colindale.



Screenshot 2

Special days can be added to the relative lighting timer channel; as special days the lighting will not operate. Special days are added by setting a day and month. Screenshot 3 shows that currently one special day is set at Colindale for 25/12 so lights will not operate on this day. Relative timers have many different number depending on vintage. Usually 41, 91, 100.1, 200.1, 300.1, 400.1, 500.1 etc.



Screenshot 3