


TYPE 'ECCA' & 'ECCB' CABINET MONITOR



NOTES:

- ON THE VOLT-FREE DEFROST INPUT (IP1), CLOSED CONTACT = DEFROST
- TO ENSURE THAT INTERNALLY FITTED SUPPRESSORS WORK CORRECTLY, CONNECT LINE VOLTAGES TO TERMINALS PREFIXED 'LN' AND CORRESPONDING LOADS TO TERMINALS PREFIXED 'LD'.
- TYPE 'ECCA-E' ONLY HAS DEFROST HEATER CONTROL FITTED. MAXIMUM LOAD 1A AT 240V ac.

OBSOLETE PRODUCT IDENTIFICATION

ECCA-B, ECCB-B, ECCA-EB



JTL SYSTEMS LTD.
41 KINGFISHER COURT, HAMBRIDGE RD,
NEWBURY, BERKSHIRE. RG14 5SJ
TEL: 01635-263646 FAX: 01635-263647

ISSUE	DESCRIPTION	APP' D	DATE
4	CHANGED PRODUCT NAME	MJK	3/94
3	ECCA-E & ECCB ADDED, CONNE REMOVED	NMT	7/91
5	NAME CHANGED	MJK	11/94

TITLE:

CABINET MONITOR WIRING

TYPE: EWECO1 (ESCMCU)

PRD.	DRG No'	SHT	OF	ISS
EC	00202	1	1	5