



IMPORTANT NOTE:

1. TO ENSURE THAT INTERNALLY FITTED SUPPRESSORS WORK CORRECTLY:-
ENSURE THAT LINE VOLTAGE IS CONNECTED TO TERMINALS LN1 - LN2
AND EACH LOAD IS CONNECTED TO THE CORRESPONDING TERMINAL LD1 - LD2.
2. INPUTS IP1 & IP2 ARE VOLT-FREE INPUTS POWERED INTERNALLY FROM THE
MAINS SUPPLY. NO EXTERNAL VOLTAGE IS TO BE APPLIED TO THEM TO AVOID
EQUIPMENT DAMAGE.
3. CONNECTORS 'CON 3' & 'CON 4' ARE NOT USED.
4. OUTPUT RELAY STATES ARE AS FOLLOWS:-
RL1 - CLOSED CONTACT = DIFF. PRESSURE VALUE ENERGISED (OPEN)
RL2 - CLOSED CONTACT = WATCHDOG HEALTHY
INPUT STATES ARE AS FOLLOWS:-
IP1 - CLOSED CONTACT = AUTO CONTROL (NO PLANT FAIL)
IP2 - CLOSED CONTACT = NOT LOW LIQUID

THIS IS AN UNCONTROLLED COPY - UNLESS STAMPED WITH CONTROLLED COPY STAMP

JTL SYSTEMS LTD 41 KINGFISHER COURT, HAMBRIDGE RD, NEWBURY, BERKSHIRE, RG14 5SJ TEL 01635-263646 FAX: 01635 263647			
ISSUE	DESCRIPTION	APP'D	DATE
3	FOR CP4H	PT	6/93
2	ADD AND CHANGE TEXT LED2-C	PT	10/92
4	REMOVED CP4L	MJK	2/99
TITLE:			
COMPRESSOR CONTROLLER WIRING			
TYPE: CP4H			
PROJ.	DRG No.	SHT	OF
CP	00531	1	1
			ISS
			4