



IMPORTANT NOTE:

1. TO ENSURE THAT INTERNALLY FITTED SUPPRESSORS WORK CORRECTLY:-
ENSURE THAT LINE VOLTAGE IS CONNECTED TO TERMINALS LN1 - LN2
AND EACH LOAD IS CONNECTED TO THE CORRESPONDING TERMINAL LD1 - LD2
2. INPUTS IP1 & IP2 ARE VOLT-FREE INPUTS POWERED INTERNALLY FROM THE
MAINS SUPPLY. NO EXTERNAL VOLTAGE IS TO BE APPLIED TO THEM TO AVOID
EQUIPMENT DAMAGE.

JTL SYSTEMS LTD.			
41 KINGFISHER COURT, HAMBRIDGE RD, NEWBURY, BERKSHIRE, RG14 5SJ TEL 01635-263646 FAX: 01635-263647			
ISSUE	DESCRIPTION	APP'D	DATE
2	UPDATED TO CPCS	JFH	9/05
1	ORIGINAL ISSUE	JFH	3/94
TITLE: COMPRESSOR CONTROLLER WIRING			
TYPE: CPCS			
PROJ.	DRG No.	SHT	OF ISS
CP	01075	1	1 2