



**IMPORTANT NOTES:**

1. TO ENSURE THAT INTERNALLY FITTED SUPPRESSORS WORK CORRECTLY:  
ENSURE THAT LINE VOLTAGE IS CONNECTED TO TERMINALS MARKED 'LN'  
AND EACH LOAD IS CONNECTED TO TERMINALS MARKED 'NO' OR 'NC'.
2. TO MEET EMC REQUIREMENTS THE CONTROLLER MUST BE INSTALLED ACCORDING  
TO THE INSTALLATION REQUIREMENTS SHEET.
3. THE LCED CONTROLLER MUST BE EARTHED TO THE CHASSIS VIA THE  
CONTROLLER FIXING HOLE AS SHOWN.
4. INPUTS REQUIRE 'C' CONNECTED TO NEUTRAL AND THE INPUT TO 230vac  
WHEN SIGNAL IS PRESENT.
5. PLANT INPUTS TO CON B MUST BE ON THE SAME PHASE AS THE SUPPLY  
ON CON A.

THIS UNIT IS NOT RATED FOR 415V

THIS IS AN UNCONTROLLED COPY - UNLESS STAMPED WITH CONTROLLED COPY STAMP

<b>JTL SYSTEMS LTD</b> 41 KINGFISHER COURT, HAMBRIDGE RD NEWBURY, BERKSHIRE, RG14 5SJ TEL: 01635 263646 FAX: 01635 263647		
ISS	DESCRIPTION	APP'D
3	UPDATED CONVERTER BOARD	MJK 2
2	ADDED CONFX4T	MJK 4
4	REMOVED CON4TSA & ADDED NOTE	MJK 8
TITLE: <b>CABINET CONTROLLER WIRING</b>		
TYPE: <b>LCED</b>		
PROJ	DRG No:	SHT OF
LC	01337	1 1