



IMPORTANT NOTE:

- TO ENSURE THAT INTERNALLY FITTED SUPPRESSORS WORK CORRECTLY:-
ENSURE THAT LINE VOLTAGE IS CONNECTED TO TERMINALS LN1 - LN2
AND EACH LOAD IS CONNECTED TO THE CORRESPONDING TERMINAL LD1 - LD2.
- INPUTS IP1 & IP2 ARE VOLT-FREE INPUTS POWERED INTERNALLY FROM THE
MAINS SUPPLY. NO EXTERNAL VOLTAGE IS TO BE APPLIED TO THEM TO AVOID
EQUIPMENT DAMAGE.
- CONNECTORS 'CON 3' & 'CON 4' ARE NOT USED.
- OUTPUT RELAY STATES ARE AS FOLLOWS:-
RL1 - CLOSED CONTACT = GAS DUMP VALVE ENERGISED
RL2 - CLOSED CONTACT = GAS TEMPERATURE VALVE ENERGISED
INPUT STATES ARE AS FOLLOWS:-
IP1 - CLOSED CONTACT = AUTO CONTROL (NO PLANT FAIL)
IP2 - CLOSED CONTACT = NOT LOW LIQUID
- GAS DUMP VALVE ONLY AVAILABLE FROM SOFTWARE V0.01.6 AND ON.

THIS IS AN UNCONTROLLED COPY - UNLESS STAMPED WITH CONTROLLED COPY STAMP

JTL SYSTEMS LTD 41 KINGFISHER COURT, HAMBRIDGE RD, NEWBURY, BERKSHIRE, RG14 5SJ TEL 01635-263646 FAX: 01635 263647		
ISSUE	DESCRIPTION	APP'D DATE
1	ORIGINAL ISSUE	MJK 7/97
TITLE: COMPRESSOR CONTROLLER WIRING		
TYPE: CP4C		
PROJ. CP	DRG No. 02025	SHT OF ISS 1 1 1