


IMPORTANT NOTE:

- TO ENSURE THAT INTERNALLY FITTED SUPPRESSORS WORK CORRECTLY:-
ENSURE THAT LINE VOLTAGE IS CONNECTED TO TERMINALS LN1 - LN2
AND EACH LOAD IS CONNECTED TO THE CORRESPONDING TERMINAL LD1 - LD2.
- INPUTS IP1 & IP2 ARE VOLT-FREE INPUTS POWERED INTERNALLY FROM THE
MAINS SUPPLY. NO EXTERNAL VOLTAGE IS TO BE APPLIED TO THEM TO AVOID
EQUIPMENT DAMAGE.
- CONNECTORS 'CON 3' & 'CON 4' ARE NOT USED.
- OUTPUT RELAY STATES ARE AS FOLLOWS:-
RL1 - CLOSED CONTACT = DIFF. PRESSURE VALUE ENERGISED (OPEN)
RL2 - CLOSED CONTACT = WATCHDOG HEALTHY
INPUT STATES ARE AS FOLLOWS:-
IP1 - CLOSED CONTACT = AUTO CONTROL (NO PLANT FAIL)
IP2 - CLOSED CONTACT = NOT LOW LIQUID

CABLE No.
CAB3
↓
MAINTENANCE
UNIT

CABLE No. CAB8

THIS IS AN UNCONTROLLED COPY - UNLESS STAMPED WITH CONTROLLED COPY STAMP

 JTL SYSTEMS LTD 41 KINGFISHER COURT, HAMBRIDGE RD, NEWBURY, BERKSHIRE, RG14 5SJ TEL 01635-263646 FAX: 01635 263647		ISSUE		DESCRIPTION	APP'D	DATE
		2	OUTPUT DETAILS CHANGED	MJK	2/01	
1	ORIGINAL ISSUE	MJK	2/99			
TITLE: COMPRESSOR CONTROLLER WIRING						
TYPE: CP4L						
PROJ.	CP	DRG No:	02412	SHT	OF	ISS
				1	1	2