



NOTE
 T2 AIR OFF TEMPERATURE
 OR
 EVAPORATOR TEMPERATURE
 WHEN ITEM 98 SET TO 3

ELECTRICAL SAFETY

THIS UNIT IS SUITABLE FOR SINGLE PHASE 230V OPERATION ONLY.
 i.e. INPUTS MUST BE ON THE SAME PHASE AS THE SUPPLY.

THIS IS AN UNCONTROLLED COPY - UNLESS STAMPED WITH CONTROLLED COPY STAMP



JTL SYSTEMS LTD
 41 KINGFISHER COURT, HAMBRIDGE RD,
 NEWBURY BERKSHIRE: RG14 5SJ
 TEL: 01635 263646 FAX: 01635 263647

ISSUE	DESCRIPTION	APP'D	DATE
3	UPDATED & ADDED DC210	MJK	03/00
5	ADDED T2 NOTE	MJK	10/17
4	ADDED DOOR TO PLANT	MJK	10/03

TITLE:
**TA210 & DC210 TEMPERATURE
 MONITOR CONNECTION DIAGRAM**

PROJ.	DRG No:	SHT	OF	ISS.
	02425	1	1	5