



NOTES:

*THE ALARM INPUT IS SELECTABLE AS GENERAL PURPOSE OR HIGH SUCTION PRESSURE INPUT. N/O OR N/C IS SELECTABLE

ELECTRICAL SAFETY

THIS UNIT HAS 3 PHASE (415V) CONNECTIONS. THE GENERAL PURPOSE ALARM INPUT MUST BE ON THE SAME PHASE AS THE CONTROL SUPPLY. NO CONNECTIONS SHOULD BE MADE TO CON5 TERMINALS 2,4,6 OR 8.

NOTE FOR USE WITH NC100/200/400/800 NETWORK CONTROLLERS

CE CONFORMANCE

This product conforms with EU standards when installed in accordance with the JTL installation requirements.

THIS IS AN UNCONTROLLED COPY – UNLESS STAMPED WITH CONTROLLED COPY STAMP

JTL SYSTEMS LTD.
4.1 KINGFISHER COURT, HAMBRIDGE RD.
NEWBURY, BERKSHIRE. RG14 5SJ
TEL: 01635-263646 FAX: 01635-263647

ISS	DESCRIPTION	APP'D	DATE
2	PHASES FIXED FOR INPUTS 1-3	MJK	1/01
1	ORIGINAL ISSUE	MJK	1/01

TITLE: **PHASE FAILURE DETECTION**

TYPE: **PA310**

PROJ. PA	DRG No: 02603	SHT 1	OF 1	ISS 2
----------	---------------	-------	------	-------