



NOTES:

- TO ENSURE THAT THE INTERNALLY FITTED SUPPRESSOR CORRECTLY:- ENSURE THAT THE LINE VOLTAGE IS CONNECTED TO TERMINALS LD1 = NO1 AND EACH LOAD IS CONNECTED TO THE CORRESPONDING TERMINAL LD2 = NO2
- INPUTS IP1 AND IP2 ARE VOLT-FREE INPUTS POWERED INTERNALLY FROM THE MAINS SUPPLY. NO EXTERNAL VOLTAGE IS TO BE APPLIED TO THEM TO AVOID EQUIPMENT DAMAGE.
- INPUT STATES ARE AS FOLLOWS:-
 IP1 - CLOSED CONTACT = AUTO CONTROL (OPEN CONTACT = PLANT FAIL)
 IP2 - CLOSED CONTACT = NOT LOW LIQUID

FUNCTION TABLE

Select output function with MU Item no 169	OUTPUT 1	OUTPUT 2
1 (CPnH)	NO SYSTEM ON GAS DEFROST	WATCHDOG HEALTHY
2 (CPnC)	OPEN GAS DUMP VALVE	OPEN GAS TEMPERATURE REGULATOR VALVE
3 (CPnA)	NO SYSTEM ON GAS DEFROST	OPEN INTERSTAGE VALVE
4 (CPnL)	NO SYSTEM ON GAS DEFROST *	WATCHDOG HEALTHY

NOTE: CONTACT CLOSED (RELAY ENERGIZED) IN STATE SHOWN
 * RELAY STATE PROGRAMMABLE USING ITEM 168

THIS IS AN UNCONTROLLED COPY - UNLESS STAMPED WITH CONTROLLED COPY STAMP

		JTL SYSTEMS LTD 41 KINGFISHER COURT, HAMBRIDGE RD, NEWBURY, BERKSHIRE: RG14 5SJ TEL: 01635 263646 FAX: 01635 263647		
		ISSUE	DESCRIPTION	APP'D
2	UPDATED TITLE & OUTPUT NOTE	MJK	12/08	
1	ORIGINAL ISSUE	MJK	12/05	
TITLE: <p style="text-align: center;">EP6U, EP6A C.P CONTROLLER WIRING</p>				
PROJ.	DRG No:	SHT	OF	ISS.
	03076	1	1	2