


PR220 & PR221 ENERGY MONITOR (kWh)



NOTE:

1. OUTPUTS ARE RATED AT 110 Vac max
100 mA max
2. OUTPUTS FITTED ON PR220 ONLY



JTL SYSTEMS LTD
41 KINGFISHER COURT, HAMBRIDGE RD,
NEWBURY, BERKSHIRE: RG14 5SJ
TEL: 01635 263646 FAX: 01635 263647

ISSUE	DESCRIPTION	APP'D	DATE
3	ADDED PR221 & NOTE 2	MJK	06/14
2	230V ac CHANGED TO ac SUPPLY	MJK	03/11
1	ORIGINAL ISSUE	MJK	11/10

TITLE:
**PR220/PR221
ENERGY MONITOR (kWh)**

PROJ.	DRG No:	SHT	OF	ISS.
	03760	1	1	3