


FL220 WATER FLOW MONITOR CONNECTIONS DRAWING

Analogue Connections

INPUT		
AI1	TP501	Not used
AI2	TP501	Not used
AI3	TP501	Not used
AI4	TP501	Not used
AI5	TP501	Not used
AI6	TP501	Not used
AI7	TP501	Not used

Digital Connections

OUTPUT		
DQ1	Unsuppressed	Watchdog
DQ2	Unsuppressed	Not used
INPUT		
DI1	Volt Free	Plant healthy
DI2	Volt Free	Flow pulse
DI3	Volt Free	Auto



NOTE

1. Connect line voltages to terminals prefixed LN and the corresponding loads to terminals prefixed DQ.



JTL SYSTEMS LTD
41 KINGFISHER COURT, HAMBRIDGE RD,
NEWBURY, BERKSHIRE: RG14 5SJ
TEL: 01635 263646 FAX: 01635 263647

ISSUE	DESCRIPTION	APPD	DATE
1	ORIGINAL ISSUE	MJK	03/17

TITLE:
FL220 WATER FLOW MONITOR
CONNECTIONS DRAWING

PROJ.	DRG No:	SHT	OF	ISS.
	04785	1	1	1