

## NJ33 \ NJ33D CONNECTIONS

## NJ33D DIN RAIL MOUNTED





**CAT5 UTP** 

To Network Controller

(screw terminal connectors)

(Note 1)

(Brown) CON 4

core

Modbus

Junction will connect between all of the following:

2 x CAB60 (RJ8 connectors)

1 x CAT5 UTP (IDC connectors)

1 x 2 core cable (Screw terminal connectors)

## NOTE:

1. Connections made to screw terminals connections should be made using unscreened 2 core cable. (eg 7/0.2-2)

If screened cable is used, the screen should ONLY be connected to earth at one end or left unconnected.

(UNDER NO CIRCUMSTANCES SHOULD THE SCREEN BE CONNECTED AT BOTH ENDS)

The flexible cable should be terminated in the correct size of boot-lace ferrule.

2. The Junction box is available in two version with (NJ33D) and without (NJ33) DIN rail mounting clips.

## THIS IS AN UNCONTROLLED COPY - UNLESS STAMPED WITH CONTROLLED COPY STAMP

ISSUE	DESCRIPTION	APP'D	DATE	:17	JTL SYSTEMS LTD. 41 KINGFISHER COURT, H.	AMBRIDG	SE RD	
1	ADDED NJ33	SzN	04/19	/1ll'	NEWBURY, BERKSHIRE. RG14 5SJ			
1	ORIGINAL ISSUE	SzN	09/18	C	TEL: 01635-263646 FAX: 01	635 2636	47	
TITLE: NJ33 \ NJ33D CONNECTION			DRG TYPE: CONNECTION DIAGRAM					
				PROJ:	DRG No:	SHT	OF	ISS.
					05139	1	1	2