

## JTL USERS CONVERSION GUIDE

### USING AN LCPC AS A REPLACEMENT PART FOR AN LCPT

---

The LCPC can be used as a replacement for LCPT controllers. The original LCPT controller only works with a mechanical expansion valve. There are no connection differences on the output relays and temperature sensor connections.

#### SUMMARY OF CONTROLLER DIFFERENCES

##### Controller Functional Differences \*

LCPC	Can be used for Electronic Expansion Valve control
LCPT	<b>Can't</b> be used for Electronic Expansion Valve control

\* Ensure that the controller is set for liquid solenoid control by setting item 160 to 0 (OFF). This is the default value so it will be so after a factory default set up (item 9 function).