

<b>JTL SOFTWARE VARIATIONS</b>		<b>CPCS</b>
<b>VERSION</b>	<b>DESCRIPTION</b>	<b>DATE</b>
v0.00.0	Derived from CPCR.	Aug 91
v0.00.1	Differential pressure relief (liquid line) valve operated at the beginning of actual defrost and not in advance using item 202. Any existing defrost interface faults cleared if item 209 switched off. Defrost inhibit time on power-up after long power down reduced from 15 to 10 minutes.	Sep 91
v0.00.2	Differential pressure relief (liquid line) valve type selectable (normally open or normally closed) on item 205. Max number of gas/electric defrosts at any time interlock introduced on item 204. Items 2x9 show number of evaporators terminated so far instead of termination pattern. Item 39 available on zone comms. Auto input shared with Plant failed input.	Sep 91