

JTL SOFTWARE VARIATIONS		ECDC
VERSION	DESCRIPTION	DATE
v0.00.1	Original issue	Jul 90
v0.00.2	Expected number of defrosts alarm added (items 69 and 95). Communications initiated defrost feature added (items 45 and 46). Item 89 added on comms. Liquid hold-off time added (item 49). Compressor pack number removed. Period over which averages are taken made variable (item 47). Bitswitch setting available on item 8. Unit type text added on maintenance unit item 0. Defrost input added (item 71). Temperature probe upper limit extended to 70C for hot gas defrost applications.	Mar 92
v0.00.3	Number of defrosts a day alarm function corrected. Unit type text added on item 6 on comms. Forced refrigeration added on item 79. Pack defrost commands cancelled when on suction initiated defrost.	Jun 93
v0.00.4	Software relinked to support 93C06 serial NVRAM. No program changes.	Feb 98