

<b>JTL SOFTWARE VARIATIONS</b>		<b>LCNL</b>
<b>VERSION</b>	<b>DESCRIPTION</b>	<b>DATE</b>
v0.00.0	Original issue	Nov 94
v0.00.1	Lighting control available with suction initiated defrost sequence. Controller shutdown via communications added. The selection function for this is on item 62. In shutdown mode refrigeration and defrost are stopped, the lights and fans outputs are on and alarms are cancelled. Communications shutdown alarm added on item 98. The shutdown command is shown on item 63.	Jan 95
v0.00.2	Software version now displayed correctly. Evaporator termination selection added on item 35. Subtype added. Defrost termination time increased to 50 mins. Fans run during forced defrost.	Nov 96