

JTL CABINET CONTROLLER ITEM NUMBERS					LCGD LCCN	
ITEM	DESCRIPTION	CODE	CODE MEANING	BIT	RANGE	ITEM 9 VALUE
				4321		
0	Unit type	LcGd Lccn	Unit type			
1	Unit number				0.0 - 899.9	
6	Communications speed	4800 600	Baud rate Baud rate			
8	Bitswitch Setting					
9	Set default values selected by Bitswitch				0 - 1	
PROCESSOR ALARMS						
10	Processor alarms (11 - 17)	0 1 - 255	No alarms Check 11 - 17			
11	Static RAM Fault	Clr rA.Ft	No fault Fault			
12	Program/counter fault	Clr PC.Ft	No fault Fault			
13	Stack pointer fault	Clr SP.Ft	No fault Fault			
14	Background loop fault	Clr bL.Ft	No fault Fault			
15	PROM checksum fault	Clr Pr.Ft	No fault Fault			
16	NVRAM fault	Clr n.Ft	No fault Fault			
17	Instruction TRAP fault	Clr tP.Ft	No fault Fault			
MISCELLANEOUS DATA						
19	Software Version number					
TEMPERATURES						
20	Estimated cabinet temperature (calculated from Air on and Air off temperatures)					
21	Air on temperature					
22	Air off temperature					
23	Evaporator temperature					
24	Suction line temperature					
25	Superheat (Evaporator temp - suction line temp)					
AVERAGE ERRORS						
26	Average cabinet temperature error					
27	Average Air off temperature error					

JTL CABINET CONTROLLER ITEM NUMBERS					LCGD LCCN	
ITEM	DESCRIPTION	CODE	CODE MEANING	BIT	RANGE	ITEM 9 VALUE
				4321		
AUTOMATICALLY ADJUSTED SETPOINTS						
28	Current Air off temperature setpoint (calculated by controller)					
29	Current Evaporator temperature setpoint (calculated by controller)					
PRIMARY TEMPERATURE SETPOINTS						
30	Cabinet temperature setpoint (target for item 20)			xxxC xxxO	- 30 to - 18 - 30 to - 18	- 20 - 26
31	Air off setpoint (starting point and lower limit for item 28)			xxxC xxxO	- 35 to - 20 - 35 to - 20	- 27 - 33
32	Overtemperature alarm tolerance				0 - 20	10
33	Cabinet temperature ratio (Item 20 calculated as value between Air off and Air on using this ratio)				20 - 100	50
PROBE SELECTION						
36	Air on probe selection	OFF A.O.En	Disabled Enabled		0 - 1	A.O.En
37	Air off probe selection	OFF A.F.En	Disabled Enabled		0 - 1	A.F.En
38	Evaporator probe selection	OFF E.P.En	Disabled Enabled		0 - 1	E.P.En
39	Suction line probe selection	OFF S.P.En	Disabled Enabled		0 - 1	S.P.En
DEFROST INFORMATION						
40	Duration of last defrost					
41	Time since end of last defrost					
42	Duration of current defrost					
45	Suction line or Comms initiated defrost selection	C.U.In S.L.In	Comms unit initiated Suction line temp initiated		0 - 1	S.L.In
46	Comms unit initiated defrost command status	P.dEF F.dEF 0	Pack on defrost Pack on forced defrost Pack not on defrost			
MISCELLANEOUS SETTINGS						
47	Period over which averages are taken				00:30 - 03:00	01:00
49	Liquid hold-off time (Initiated by comms defrost command)				00:00 - 00:10	00:00

JTL CABINET CONTROLLER ITEM NUMBERS					LCGD LCCN	
ITEM	DESCRIPTION	CODE	CODE MEANING	BIT	RANGE	ITEM 9 VALUE
				4321		
DEFROST SETPOINTS						
50	Defrost termination temperature (Air off probe)				0 - 20	15
57	Defrost termination time limit				00:05 - 00:40	00:15
58	Defrost initiation temperature (Suction line probe)				- 5 to +20	0
69	Number of defrosts expected per day	0 1 - 6	Disable alarm 94 Alarm enabled		0 - 6	3
MODES, INPUTS AND OUTPUTS						
70	Operating mode	rEFr dEFr dF.rc	Refrig. Defrost Defrost recovery			
72	Auxiliary heater relay	OFF Hr.on	Contacts open Contacts closed			
73	Fans relay	OFF Fn.on	Contacts open Contacts closed			
74	Defrost relay	OFF dt.on	Contacts open Contacts closed			
75	Liquid solenoid relay	OFF LS.on	Off Demanding refriger.			
76	Defrost relay mode selection	d.tEr d.con	Defrost termination Defrost control		0 - 1	d.tEr
FORCING FUNCTIONS						
Forced functions remain forced if the Maintenance unit remains plugged in. They are automatically cancelled 30 minutes after the Maintenance unit is unplugged.						
77	Forced defrost	OFF Fd.on	Off Forced defrost on		0 - 1	
78	Forced refrigeration	OFF no.dF	Off No defrosts		0 - 1	

JTL CABINET CONTROLLER ITEM NUMBERS					LCGD LCCN	
ITEM	DESCRIPTION	CODE	CODE MEANING	BIT	RANGE	ITEM 9 VALUE
				4321		
SYSTEM ALARMS						
80	Group alarm 81 - 88	0 1 - 255	No alarms Check 81 - 88			
81	Cabinet overtemperature	CLr C.Ht	No fault Fault			
82	Air off overtemperature	CLr A.Ht	No fault Fault			
83	Air on probe fault	CLr AO.Pr	No fault Fault			
84	Air off probe fault	CLr AF.Pr	No fault Fault			
85	Thermistor power supply fault	CLr PS.Ft	No fault Fault			
87	Unit number corrupted/not set	CLr Un.CF	No fault Fault			
88	All probes faulty, deselected or disconnected	CLr t.SEn	No fault Fault			
MISCELLANEOUS DATA						
89	Thermistor excitation value (Factory test)		Not used			
SYSTEM ALARMS						
90	Group alarm 91-98	0 1 - 255	No alarms Check 91 - 98			
92	Evaporator probe fault	CLr EP.Pr	No fault Fault			
93	Suction line probe fault	CLr SL.Pr	No fault Fault			
94	Expected defrosts have not been detected	CLr dEF.F	No fault Fault			
UTILITY						
99	Test digital display	CLr SEt	Not active Test active		0 - 1	
COMPRESSOR PACK DATA						
101	Air off setpoint for compressor pack					
PROBE TYPE SELECTION (LCCN only)						
102	LCCN probe type selection	5000 2000	JTL Elm		0 - 1	2000

BITSWITCH SETTINGS

4321

xxx**C** Frozen food
 xxx**O** Ice cream

where **C** = CLOSED or ON
 O = OPEN or OFF
 x = Don't care

Note 1: For unmarked switches
 C = dot visible
 O = dot not visible

Note 2: Setting the bitswitches alone has no effect.
 Use **ITEM 9** to set the default values after the switches are set.

DISPLAY DATA		LCGD
		LCCN
NORMAL DISPLAY		
- 99 ^c	Cabinet temperature (item 20 rounded)	
dEF	Defrost	
dEFr	Defrost recovery	
--	Display data error	
ALARM TEXT (in descending priority order)		
t.SEn	All probes faulty, deselected or disconnected	
Ht	High cabinet or air off temperature	
OTHER TEXT		
JTL	Start-up text	