

## JTL ALARM DISPLAY MESSAGES

JTL	JTL Logo - No alarms	CPrd	Pack D Compressor fault	CASL	Refrigerant Gas leak	HtCd	HT condensor fault	NRnO	Manual override	ES-1	Thermistor 1 fault
--	No alarms	CPth	Motor thermistor fault	GENF	Generator failure	HtCP	HT compressor fault	nodF	Defrost not detected	ES-7	Thermistor 7 fault
Ad 5	Unit alarms Disabled	Cr it	Critical Alarm	H AL	High level alarm	HtLL	HT low liquid level	O, IP	Oil pressure fault	ESEn	All sensors faulty
AOFF	Air - off thermistor	CFrA	Pack A Com timer fault	H iAL	High air - off temperature	HtLo	High temperature warning time out	OPdi	Operation disabled	UnNo	Unit no corrupt
AOon	Air - on thermistor	CFrB	Pack B Com timer fault	H idP	High discharge pressure	UnEt	Jnet communications fault	PFLt	Probe faulty		
ASSt	Asset warning	CU-1	Condensing Unit 1 fault	H idt	High discharge temperature	L1CP	LT1 Compressor fault	PHFL	Phase failure		
Ch-1	Channel 1 alarm	CU-8	Condensing Unit 8 fault	H iHE	High HT suction pressure	L2CP	LT2 Compressor fault	PLC	PLC backup fault		
Ch-8	Channel 8 alarm	dIAL	Dial out test alarm	H iL1	High level liquid	L1LL	LT1 low liquid level	P-dL	Pump overload		
Con	Condensor fault	dLF1	Data link fault	H iLt	High LT suction pressure	L2LL	LT2 low liquid level	P-Pd	Pump pressure difference		
ConA	Pack A Condensor fault	dLoG	Data logger failed	H ion	High coolant temperature	LoAL	low level alarm	PSEn	Pressure transducer fault		
Conb	Pack B Condensor fault	dOFt	Dial out fault	H iSA	Pack A - High suction pressure	LoLA	Pack A - Low liquid level	PSU	Thermistor power supply faulty		
ConC	Pack C Condensor fault	door	Door open	H iSb	Pack B - High suction pressure	LoLb	Pack B - Low liquid level	PuOr	Pump overrun		
ConD	Pack D Condensor fault	drn	Drain blocked	H iSc	Pack C - High suction pressure	LoLc	Pack C - Low liquid level	rEFL	Refrigerant loss		
CPAC	Pack fault	ELEC	Electric supply fault	H iSd	Pack D - High suction pressure	LoLd	Pack D - Low liquid level	rUUn	Rejected unit		
CPr	Compressor fault	E-SH	Excessive superheat	H iSP	High suction pressure	LoL1	Low liquid level	Shdn	Unit Shutdown via network		
CPr1	Compressor 1 fault	FAIL	Communications failure	H iSt	High satellite pressure	LoOL	Low oil level	StEP	Step controller fault		
CPr6	Compressor 6 fault	FAn	Fan failure	HPLP	Pressure lockout fault	LoSh	Low superheat	Stub	Stub interface fault		
CPrA	Pack A Compressor fault	FArA	Pack A Condensor fault	Ht	High temperature	LoSP	Low suction pressure	SYSF	System fault		
CPrB	Pack B Compressor fault	FArB	Pack B Condensor fault	Ht-1	High temperature channel 1	Lt	Low temperature	tFLt	Timer fault		
CPrC	Pack C Compressor fault	GASd	Gas Leak Detector fault	Ht-7	High temperature channel 7	LtCd	LT Condensor fault	tRAP	Man trapped		