


A PORTION OF TEMPERATURE HISTORY PRINTOUT

	1hr Intervals	
	Store Ident and Logalert No	
Time Intervals of Temp Recordings →	• # • 1 - 0 0 • # • • 0 1 0 2 - 2	
Date & Time of Printout →	• 1 8 - 0 7 - 9 7 • • 2 3 • 5 9 •	
Channel/Unit numbers →	• 1 • • • 2 • • • 3 • • • 4 • • •	
Temperatures at 23:59hrs →	- 2 2 • - 2 1 • - 2 0 • • 0 1 • •	
Temperatures at 22:59hrs →	- 2 1 • - 1 8 • - 1 8 • • 0 1 • •	
Temperatures at 21:59hrs →	- 1 9 • • # # • • # # • • 0 0 • •	Units 2 & 3 on defrost
Temperatures at 20:59hrs →	• # # • - 2 3 • - 2 4 • • # # • •	Units 1 & 4 on defrost
Temperatures at 19:59hrs →	- 2 3 • - 2 2 • - 2 4 • • 0 2 • •	
Temperatures at 18:59hrs →	- 2 3 • - 2 2 • - 2 3 • • 0 2 • •	
Temperatures at 17:59hrs →	- 2 2 • - 2 1 • - 2 1 • • 0 1 • •	
Temperatures at 16:59hrs →	- 2 2 • - 1 9 • - 1 8 • • 0 2 • •	
Temperatures at 15:59hrs →	- 1 9 • - 1 9 • • # # • • 0 2 • •	Unit 3 on defrost
Temperatures at 14:59hrs →	• # # • - 1 8 • - 2 4 • • 0 3 • •	Unit 1 on defrost
Temperatures at 13:59hrs →	- 2 2 • • # # • • - 2 3 • • 0 4 • •	Unit 2 on defrost
Temperatures at 12:59hrs →	• 2 3 • - 2 3 • - 2 2 • • # # • •	Unit 4 on defrost
Same for Channel/Unit No →	• 5 • • • 6 • • • 7 • • • • • • • •	
	• # # • • 0 4 • • # # • • • • • • • •	
	• 0 1 • • 0 0 • • 0 0 • • • • • • • •	

Please note The printout repeats in twelve hour blocks for ten day period ie, 40 blocks total.

	• # • 1 - 0 0 • # • • 0 1 0 2 - 2	
	• 1 8 - 0 7 - 9 7 • • 1 1 • 5 9 •	
	• 1 • • • 2 • • • 3 • • • 4 • • •	
11:59hrs →	- 2 2 • - 2 1 • - 2 0 • • 0 1 • •	
10:59hrs →	- 2 1 • - 1 8 • - 1 8 • • 0 1 • •	
09:59hrs →	- 1 9 • • 1 7 • • # # • • 0 0 • •	

Please note That the Temperature Recording periods can be set to 15min - 30min - 1 hour or 2 hour Intervals to suit requirements, and that the above 10 day period is also settable.

ISSUE	DESCRIPTION	APP'D	DATE						
1	ORIGINAL ISSUE	MJK	2/99	 JTL SYSTEMS LTD. 41 KINGFISHER COURT, HAMBRIDGE RD, NEWBURY, BERKSHIRE. RG14 5SJ TEL: 01635-263646 FAX: 01635 263647					
TITLE:									
TEMPERATURE HISTORY PRINT OUT DIAGRAM				PROJ:	DRG No:	02401	SHT	OF	ISS.
						1	1	1	