



- NOTES:**
1. ZONES 1 TO 5 ARE FOR CONTROLLERS & MONITORS. THE PLANT ALARM ZONE IS FOR SIMPLE INTERFACE EQUIPMENT.
 2. ZONES 1 TO 5 CAN ACCOMODATE UP TO 31 UNITS, THE PLANT ALARM ZONE IS LIMITED TO A MAXIMUM OF 5 UNITS.
 3. SIMPLE PLUG IN JUMPER CABLES ARE AVAILABLE FOR CONNECTING DISPLAY CABINETS TOGETHER.
 4. FOR CONNECTIONS TO SITE PC SEE DRG 02717 FOR NEW INSTALLATIONS UNTIL MAY 2001 OR DRG 02720 FOR INSTALLATIONS AFTER MAY 2001.

JTL SYSTEMS LTD.
 41 KINGFISHER COURT, HAMBRIDGE RD,
 NEWBURY, BERKSHIRE. RG14 5SJ
 TEL: 01635-263646 FAX: 01635-263647

ISS	DESCRIPTION	APP'D	DATE
3	UPDATED NAME OF CONTROLLER	MJK	4/00
5	REMOVED LINE DRIVER CONNECTION. CHANGED NOTE4	MJK	11/01
4	CHANGED PC - NETWORK CONTROLLER	MJK	05/01

TITLE: NETWORK CONTROLLER EXTERNAL WIRING

TYPE: CU5

PROJ.	CC	DRG No:	00613	SHT	1	OF	1	ISS	5
-------	----	---------	-------	-----	---	----	---	-----	---

THIS IS AN UNCONTROLLED COPY - UNLESS STAMPED WITH CONTROLLED COPY STAMP