



NOTES:

1. THE DEFROST OUTPUT IS A CHANGE OVER CONTACT ALLOWING CHOICE OF N/O OR N/C VALVES. THIS OUTPUT SEQUENCE CAN ALSO BE VARIED (SEE ITEM DATA).
2. AUXILLIARY HEATER/FANS OUTPUT SEQUENCE CAN BE VARIED (SEE ITEM DATA).
3. TO MEET EMC REQUIREMENTS THE CONTROLLER MUST BE INSTALLED ACCORDING TO THE INSTALLATION REQUIREMENTS SHEET FOR THIS PRODUCT.
4. THE LCNB/LCDC CONTROLLERS MUST BE EARTHED TO THE CHASSIS VIA THE CONTROLLER FIXING HOLE AS SHOWN.
5. INPUTS REQUIRE 'C' CONNECTED TO NEUTRAL AND THE INPUT TO 230Vac WHEN SIGNAL IS PRESENT.
6. PLANT INPUTS TO CON B MUST BE ON THE SAME PHASE AS THE SUPPLY ON CON A.
THIS UNIT IS NOT RATED FOR 415V.

THIS IS AN UNCONTROLLED COPY - UNLESS STAMPED WITH CONTROLLED COPY STAMP

JTL SYSTEMS LTD. 41 KINGFISHER COURT, HAMBRIDGE RD, NEWBURY, BERKSHIRE, RG14 5SJ TEL: 01635-263646 FAX: 01635-263647			
ISS	DESCRIPTION	APP'D	DATE
6	ADDED NOTE FOR LCD DISPLAYS	MJK	11/00
5	REMOVED CON BOARDS, ADDED NOTE	MJK	7/98
4	CORRECTED CON7TS	MJK	4/97
TITLE: CABINET CONTROLLER & ASSOCIATED PARTS			
TYPE: LCNB, LCDC			
PROJ. LC	DRG No: 01373	SHT 1 OF 1	ISS. 6