



NOTES:

1. THE DEFROST AND AUXILLIARY OUTPUTS ARE CHANGEOVER CONTACTS. SELECT THE APPROPRIATE OUTPUT FOR THE APPLICATION.
2. TO MEET EMC REQUIREMENTS THE CONTROLLER MUST BE INSTALLED ACCORDING TO THE INSTALLATION REQUIREMENTS SHEET FOR THIS PRODUCT.
3. THE LCED CONTROLLER MUST BE EARTHED TO THE CHASSIS VIA THE CONTROLLER FIXING HOLE AS SHOWN.
4. INPUTS REQUIRE 'C' CONNECTED TO NEUTRAL AND THE INPUT TO 230Vac WHEN SIGNAL IS PRESENT.
5. PLANT INPUTS TO CON B MUST BE ON THE SAME PHASE AS THE SUPPLY ON CON A.
THIS UNIT IS NOT RATED FOR 415V

THIS IS AN UNCONTROLLED COPY - UNLESS STAMPED WITH CONTROLLED COPY STAMP

		JTL SYSTEMS LTD. 41 KINGFISHER COURT, HAMBRIDGE RD, NEWBURY, BERKSHIRE. RG14 5SJ TEL: 01635-263646 FAX: 01635-263647	
		ISS	DATE
6	UPDATED CONVERTER BOARD	MJK	11/00
5	REMOVED CON4TSA & ADDED NOTE	MJK	8/98
4	CON C CORRECTED TO 'NO'	MJK	4/97
TITLE: CABINET CONTROLLER & ASSOCIATED PARTS			
TYPE: LCED			
PROJ.	DRG No:	SHT	OF
LC	01500	1	1
			ISS.
			6