



NOTES:

1. THE DEFROST OUTPUT 1 & 2 ARE CHANGE OVER CONTACTS ALLOWING CHOICE OF N/O OR N/C VALVES.
2. DEFROST 3/AUXILLIARY HEATER/FANS OUTPUT SEQUENCE CAN BE VARIED (SEE ITEM DATA).
3. TO MEET EMC REQUIREMENTS THE CONTROLLER MUST BE INSTALLED ACCORDING TO THE INSTALLATION REQUIREMENTS SHEET FOR THIS PRODUCT.
4. THE LCID CONTROLLER MUST BE EARTHED TO THE CHASSIS VIA THE CONTROLLER FIXING HOLE AS SHOWN.
5. INPUTS REQUIRE 'C' CONNECTED TO NEUTRAL AND THE INPUT TO 230Vac WHEN SIGNAL IS PRESENT.
6. PLANT INPUTS TO CON B MUST BE ON THE SAME PHASE AS THE SUPPLY TO CON A.
THIS UNIT IS NOT RATED FOR 415V

THIS IS AN UNCONTROLLED COPY - UNLESS STAMPED WITH CONTROLLED COPY STAMP

JTL SYSTEMS LTD. 41 KINGFISHER COURT, HAMBRIDGE RD, NEWBURY, BERKSHIRE, RG14 5SJ TEL: 01635-263646 FAX: 01635-263647				
ISS	DESCRIPTION	APP'D	DATE	
6	UPDATED CONVERTER BOARD	MJK	11/00	
5	REMOVED CON'TS	MJK	4/96	
4	CON C CORRECTED TO 'NO'	MJK	4/97	
TITLE: CABINET CONTROLLER & ASSOCIATED PARTS				
TYPE: LCID				
PROJ. LC	DRG No: 01501	SHT 1	OF 1	ISS. 6