


**NOTES:**

1. THE DEFROST OUTPUT HAS CHANGEOVER CONTACTS. SELECT THE APPROPRIATE OUTPUT FOR THE APPLICATION.
2. THE LIQUID SOLENOID VALVE MAY BE USED AS AN ALTERNATIVE TO THE PEV OUTPUT WHEN USING A CONVENTIONAL TEV.
3. THE LCIS CONTROLLER MUST BE EARTHED TO THE CHASSIS VIA THE CONTROLLER FIXING HOLE AS SHOWN.
4. TO MEET EMC REQUIREMENTS THE CONTROLLER MUST BE INSTALLED ACCORDING TO THE INSTALLATION REQUIREMENTS SHEET FOR THIS PRODUCT.
5. INPUTS REQUIRE 'C' CONNECTED TO THE NEUTRAL AND THE INPUT TO 230Vac WHEN SIGNAL IS PRESENT.
6. IF ITEM 138 SET ON THEN A CLOSED CONTACT ON INPUT 2 PUTS COLDROOM INTO SHUTDOWN MODE.

THIS IS AN UNCONTROLLED COPY - UNLESS STAMPED WITH CONTROLLED COPY STAMP

		<b>JTL SYSTEMS LTD.</b> 41.KINGFISHER COURT, HAMBRIDGE RD, NEWBURY, BERKSHIRE. RG14 5SJ TEL: 01635-263646 FAX: 01635-263647	
		ISS	DESCRIPTION
6	ADDED NOTE 6	MJK	6/00
5	REMOVED CON4PT BOARD	MJK	7/98
4	ADDED CAB3 & NOTE 6	MJK	7/96
TITLE: COLDSTORE CONTROLLER & ASSOCIATED PARTS			
TYPE: LCIS			
PROJ	DRG No:	SHT	OF
LC	01658	1	1
			ISS
			6