



NOTES:

1. THE DEFROST OUTPUT IS A CHANGE OVER CONTACT ALLOWING CHOICE OF N/O OR N/C VALVES. THIS OUTPUT SEQUENCE CAN ALSO BE VARIED (SEE ITEM DATA).
2. TO MEET EMC REQUIREMENTS THE CONTROLLER MUST BE INSTALLED ACCORDING TO THE INSTALLATION REQUIREMENTS SHEET FOR THIS PRODUCT.
3. THE LCIL & LCPL CONTROLLERS MUST BE EARTHED TO THE CHASSIS VIA THE CONTROLLER FIXING HOLE AS SHOWN.
4. INPUTS REQUIRE 'C' CONNECTED TO NEUTRAL AND THE INPUT TO 230Vac WHEN SIGNAL IS PRESENT.
5. PLANT INPUTS TO CON B MUST BE ON THE SAME PHASE AS THE SUPPLY ON CON A.
THIS UNIT IS NOT RATED FOR 415V

THIS IS AN UNCONTROLLED COPY - UNLESS STAMPED WITH CONTROLLED COPY STAMP

FOR LINDE 'ATR' WITH SINGLE EVAPORATOR.

JTL SYSTEMS LTD.
41 KINGFISHER COURT, HAMBRIDGE RD,
NEWBURY, BERKSHIRE, RG14 5SJ
TEL: 01635-263626 FAX: 01635-263647

ISS	DESCRIPTION	APP'D	DATE
3	ADDED NOTE FOR LCD DISPLAYS	MJK	11/00
5	SWAPPED INPUTS	MJK	3/01
4	ADDED LCPL	MJK	1/01

TITLE:
CABINET CONTROLLER & ASSOCIATED PARTS - (FOR LINDE)

TYPE: LCIL & LCPL

PROJ	DRG No:	SHT	OF	ISS.
LC	01990	1	1	5