



NOTES:

1. THE DEFROST OUTPUT HAS CHANGEOVER CONTACTS. SELECT THE APPROPRIATE OUTPUT FOR THE APPLICATION.
2. ON LCPC THE LIQUID SOLENOID VALVE MAY BE USED AS AN ALTERNATIVE TO THE PEV OUTPUT WHEN USING A CONVENTIONAL TEV.
3. THE LCPC CONTROLLER MUST BE EARTHED TO THE CHASSIS VIA THE CONTROLLER FIXING HOLE AS SHOWN.
4. TO MEET EMC REQUIREMENTS THE CONTROLLER MUST BE INSTALLED ACCORDING TO THE INSTALLATION REQUIREMENTS SHEET FOR THIS PRODUCT.
5. INPUTS REQUIRE 'C' CONNECTED TO THE NEUTRAL AND THE INPUT TO 230vac WHEN SIGNAL IS PRESENT.
6. PLANT INPUTS TO CON B MUST BE ON THE SAME PHASE AS THE SUPPLY ON CON A.
THIS UNIT IS NOT RATED FOR 415V.
7. FANS/HEATER OUTPUT SELECTABLE USING MAINTENANCE UNIT.
8. ON LCPT RL5 OUTPUT IS FOR LIQUID SOLENOID ONLY.

THIS IS AN UNCONTROLLED COPY - UNLESS STAMPED WITH CONTROLLED COPY STAMP

JTL SYSTEMS LTD. 41 KINGFISHER COURT, HAMBRIDGE RD, NEWBURY, BERKSHIRE, RG14 5SJ TEL: 01635-26364 FAX: 01635-263647			
ISS	DESCRIPTION	APP'D	DATE
3	ADDED NOTE FOR LCD DISPLAY	MJK	11/00
2	REMOVED CON BOARDS, ADDED NOTE	MJK	7/98
4	SWAPPED INPUTS	MJK	3/01
TITLE: CABINET CONTROLLER & ASSOCIATED PARTS			
TYPE: LCPC, LCPT			
PROJ	DRG No:	SHT	OF
LC	02086	1	1
			ISS.
			4