



**NOTES:**

1. THE SDPN ENCLOSURE MUST BE EARTHED.
2. TO MEET EMC REQUIREMENTS THE CONTROLLER MUST BE INSTALLED ACCORDING TO THE INSTALLATION REQUIREMENTS SHEET FOR THIS PRODUCT.
3. INPUT REQUIRE 'C' CONNECTED TO THE NEUTRAL AND THE INPUT TO 230Vac WHEN SIGNAL IS PRESENT.
4. CONNECTIONS TO CON2 & 3 MUST BE ON THE SAME PHASE AS THE SUPPLY ON CON 1.  
THIS UNIT IS NOT RATED FOR 415V
5. FROM FIRMWARE VERSION 0.00.1 PIPE SENSORS ARE SUPPORTED AS A COMMISSIONING OPTION.
6. FROM FIRMWARE VERSION 0.00.4 FOR LEGACY PURPOSES 2K & 2K2 SENSOR ARE SUPPORTED AS WELL AS THE STANDARD 5K SENSOR (ITEM 102).
7. FROM FIRMWARE VERSION 0.00.4 LEGACY DISPLAYS ARE ALSO SUPPORTED (ITEM 129). APPROPRIATE PARTS ARE AVAILABLE TO CONVERT DISPLAYS FOR USE WITH THE SDPN. CONTACT THE JTL SALES DEPARTMENT.

THIS IS AN UNCONTROLLED COPY - UNLESS STAMPED WITH CONTROLLED COPY STAMP

<b>JTL SYSTEMS LTD</b> 41 KINGFISHER COURT, HAMBRIDGE RD, NEWBURY, BERKSHIRE: RG14 5SJ TEL: 01635 263646 FAX: 01635 263647			
ISSUE	DESCRIPTION	APP'D	DATE
3	ADDED NOTES 6 & 7	MJK	10/05
2	ADDED NOTE 5	MJK	04/04
1	ORIGINAL ISSUE	MJK	09/01
TITLE: CABINET CONTROLLER & ASSOCIATED PARTS			
TYPE: SDPN			
PROJ.	DRG No: 02680	SHT 1 OF 1	ISS. 3