



NOTES:

1. THE DEFROST OUTPUT HAS CHANGEOVER CONTACTS. SELECT THE APPROPRIATE OUTPUT FOR THE APPLICATION.
2. THE LAPN CONTROLLER MUST BE EARTHED TO THE CHASSIS VIA THE CONTROLLER FIXING HOLE AS SHOWN.
3. TO MEET EMC REQUIREMENTS THE CONTROLLER MUST BE INSTALLED ACCORDING TO THE INSTALLATION REQUIREMENTS SHEET FOR THIS PRODUCT.
4. INPUTS REQUIRE 'C' CONNECTED TO THE NEUTRAL AND THE INPUT TO 230Vac WHEN SIGNAL IS PRESENT.
5. PLANT INPUTS TO CON B MUST BE ON THE SAME PHASE AS THE SUPPLY ON CON A.
THIS UNIT IS NOT RATED FOR 415V
6. FANS/HEATER OUTPUT SELECTABLE USING MAINTENANCE UNIT.
7. FROM V0.00.6 FIRMWARE LEGACY DISPLAYS LCD1-7, 10 & 12 ARE SUPPORTED.

		JTL SYSTEMS LTD. 41 KINGFISHER COURT, HAMBRIDGE RD, NEWBURY, BERKSHIRE. RG14 5SJ TEL: 01635-263646 FAX: 01635-263647	
ISS	DESCRIPTION	APP'D	DATE
3	UPDATED	MJK	03/04
2	RENAMED & ADDED CON7	MJK	12/03
4	NOTE 7 ADDED	MJK	04/07
TITLE: CABINET CONTROLLER & ASSOCIATED PARTS SCHEMATIC			
TYPE: LAPN			
PROJ.	DRG No:	SHT	OF
LA	02876	1	1
			ISS.
			4

THIS IS AN UNCONTROLLED COPY - UNLESS STAMPED WITH CONTROLLED COPY STAMP