

## NOTES;

- THE DEFROST OUTPUT HAS CHANGEOVER CONTACTS.
  SELECT THE APPROPRIATE OUTPUT FOR THE APPLICATION.
- 2. THE LAPE CONTROLLER MUST BE EARTHED TO THE CHASSIS VIA THE CONTROLLER FIXING HOLE AS SHOWN.
- 3. TO MEET EMC REQUIREMENTS THE CONTROLLER MUST BE INSTALLED ACCORDING TO THE INSTALLATION REQUIREMENTS SHEET FOR THIS PRODUCT.
- 4. INPUTS REQUIRE `C' CONNECTED TO THE NEUTRAL AND THE INPUT TO 230Vac WHEN SIGNAL IS PRESENT.

- 5. PLANT INPUTS TO CON B MUST BE ON THE <u>SAME</u> PHASE AS THE SUPPLY ON CON A.
- THIS UNIT IS NOT RATED FOR 415V
- 6. FANS/HEATER OUTPUT SELECTABLE USING MAINTENANCE UNIT.



THIS IS AN UNCONTROLLED COPY - UNLESS STAMPED WITH CONTROLLED COPY STAMP