

- 3. TO MEET EMC REQUIREMENTS THE CONTROLLER MUST BE INSTALLED
- 4. INPUTS REQUIRE `C' CONNECTED TO THE NEUTRAL AND THE INPUT TO 230Vac WHEN SIGNAL IS PRESENT.
- 5. INPUTS MUST BE ON THE  $\underline{\mathsf{SAME}}$  PHASE AS THE SUPPLY. THIS UNIT IS NOT RATED FOR 415V
- 6. LCD13 SUPPORTED FROM VERSION 0.00.5 FIRMWARE.



JTL SYSTEMS LTD. 41 KINGFISHER COURT, HAMBRIDGE RD, NEWBURY, BERKSHIRE. RG14 5SJ TEL: 01635-263646 FAX: 01635-263647

DESCRIPTION APP'D DATE 2 ADDED CAB75 CONNECTION & NOTE 6 MJK 11/08 1 ORIGINAL ISSUE MJK 06/04

TITLE: COLDROOM CONTROLLER & ASSCOCIATED PARTS SCHEMATIC

TYPE: LACN

OF 03098 1 1

THIS IS AN UNCONTROLLED COPY - UNLESS STAMPED WITH CONTROLLED COPY STAMP