


**NOTES:**

1. DEFROST OUTPUTS 2-4 HAVE CHANGEOVER CONTACTS. SELECT THE APPROPRIATE OUTPUT FOR THE APPLICATION.
2. THE LACT CONTROLLER MUST BE EARTHED TO THE CHASSIS VIA THE CONTROLLER FIXING HOLE AS SHOWN.
3. TO MEET EMC REQUIREMENTS THE CONTROLLER MUST BE INSTALLED ACCORDING TO THE INSTALLATION REQUIREMENTS SHEET FOR THIS PRODUCT.
4. INPUTS REQUIRE 'C' CONNECTED TO THE NEUTRAL AND THE INPUT TO 230Vac WHEN SIGNAL IS PRESENT.
5. INPUTS MUST BE ON THE SAME PHASE AS THE SUPPLY. THIS UNIT IS NOT RATED FOR 415V
6. LCD13 SUPPORTED FROM VERSION 0.00.3 FIRMWARE.

THIS IS AN UNCONTROLLED COPY - UNLESS STAMPED WITH CONTROLLED COPY STAMP

 <b>JTL SYSTEMS LTD.</b> 4J KINGFISHER COURT, HAMBRIDGE RD, NEWBURY, BERKSHIRE. RG14 5SJ TEL: 01635-263646 FAX: 01635-263647		ISS	
		DESCRIPTION	APP'D DATE
2	ADDED CAB75 WITH DISPLAY & NOTE 6	MJK	11/08
1	ORIGINAL ISSUE	MJK	02/07
TITLE: COLDROOM CONTROLLER & ASSOCIATED PARTS SCHEMATIC			
TYPE: LACT			
PROJ.	DRG No:	SHT OF	ISS.
LA	03327	1 1	2