

OUTPUT FUNCTION TABLE FOR CP5H & EP6U


Select output function with MU Item 169	OUTPUT 1	OUTPUT 2
1 (CPnH)	NO SYSTEM ON GAS DEFROST	WATCHDOG HEALTHY
2 (CPnC)	OPEN GAS DUMP VALVE	OPEN GAS TEMPERATURE REGULATOR VALVE
3 (CPnA)	NO SYSTEM ON GAS DEFROST	OPEN INTERSTAGE VALVE
4 (CPnL)	NO SYSTEM ON GAS DEFROST	WATCHDOG HEALTHY

NOTE: CONTACT CLOSED (RELAY ENERGIZED) IN STATE SHOWN.

* RELAY STATE PROGRAMMABLE USING ITEM 168.

APPLICABLE TO CP5H SOFTWARE VERSION 6 AND LATER VERSIONS.

THIS IS AN UNCONTROLLED COPY UNLESS STAMPED WITH CONTROLLED COPY STAMP

ISSUE	DESCRIPTION	APP'D	DATE		
2	ADDED NEW PRODUCT EP6U	MJK	04/02		JTL SYSTEMS LTD. 41 KINGFISHER COURT, HAMBRIDGE RD, NEWBURY, BERKSHIRE. RG14 5SJ TEL: 01635-263646 FAX: 01635 263647
1	ORIGINAL ISSUE	MJK	03/00		
TITLE:					
OUTPUT FUNCTION TABLE FOR CP5H & EP6U				PROJ:	DRG No: 02527
				SHT	OF
				1	1
				ISS.	2